

NOTES

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION FOR ELECTRICAL SERVICES INSTALLATION AND ALL ASSOCIATED ELECTRICAL DRAWINGS LISTED THEREIN.
2. ALL ELECTRICAL SERVICES DRAWINGS SHALL BE READ IN CONJUNCTION WITH ALL ASSOCIATED ARCHITECTURAL, STRUCTURAL, DRAINAGE AND MECHANICAL SERVICES DRAWINGS.
3. THE CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS ON SITE PRIOR TO COMMENCING CONSTRUCTION.
4. ASBESTOS MAY BE PRESENT IN ANY PART OF THE BUILDING. THE ASBESTOS REGISTER SHOULD BE CONSULTED PRIOR TO ALL WORKS, AND ALL SITE OPERATIVES SHALL BE TRAINED IN ASBESTOS AWARENESS.

P2	14/10/22	STAGE 3 ISSUE
P1	07/10/22	PRELIMINARY FOR ARCHITECT'S COMMENT
REV	DATE	DESCRIPTION



CLIENT	ST LAWRENCE CHURCH PCC
PROJECT	PROJECT INSPIRE ST LAWRENCE CHURCH LECHLADE
TITLE	GALLERY / HIGH LEVEL PROPOSED LIGHTING, EMERGENCY LIGHTING AND FIRE ALARM LAYOUT
DRAWN	KH / IP
CHECKED	IP / PQ
DRAWING No.	4184 E 02
SCALE	1:50 @ A0
DATE	SEP 2022
REVISION	P2

SCHEDULE OF LUMNAIRES	
S1	LED FLOODLIGHT, BLACK FINISH W/ 3 CIRCUIT TRACK ADAPTER, 28W OVAL FLOOD AT HIGH LEVEL, 4000K COLOUR TEMPERATURE, DALI CONTROL. O - DENOTES LUMINAIRE TO DIRECTED AT ORGAN P - DENOTES LUMINAIRE TO DIRECTED AT PULPIT F - DENOTES LUMINAIRE TO DIRECTED AT FONT PI - DENOTES LUMINAIRE TO DIRECTED AT PIANO C - DENOTES LUMINAIRE TO DIRECTED AT CHAIR A - DENOTES LUMINAIRE TO DIRECTED AT ALTAR CA - DENOTES LUMINAIRE TO DIRECTED AT COAT OF ARMS
S2	LED FLOODLIGHT, BLACK FINISH W/ 3 CIRCUIT TRACK ADAPTER, 28W OVAL FLOOD AT HIGH LEVEL, 4000K COLOUR TEMPERATURE, DALI CONTROL, POSITIONED TO UPLIGHT CEILING.
S3	AS S2 STYLE BUT WITH LOWER OUTPUT
B1	LED SPOTLIGHT WITH ADJUSTABLE BEAM ANGLE, 2.7K COLOUR TEMPERATURE, DALI CONTROL, BLACK FINISH MOUNTED AT HIGH LEVEL, AIMED DOWN.
C	SURFACE MOUNTED / RECESSED LED DOWNLIGHT
CE	AS TYPE 'F' BUT FITTED WITH 3 HOUR NON MAINTAINED EMERGENCY INTEGRAL BATTERY INVERTER UNIT.
D	LINEAR, 22.5MM, 3000K RIGID LED STRIP TAPE COMPLETE WITH DRIVER.
E1	SURFACE MOUNTED BLACK 3 WAY SELF CONTAINED, NON MAINTAINED LED EMERGENCY LUMINAIRE, 3 HOUR DURATION.
E2	HIGH LEVEL, SURFACE MOUNTED BLACK 3 WAY NON MAINTAINED LED EMERGENCY LUMINAIRE, 3 HOUR DURATION.
F	LED WALL LIGHT

LIGHTING LEGEND	
✓	1500A 1 GANG 1 WAY LIGHTING SWITCH G - DENOTES NUMBER OF GANGS
⊙	PRESSENCE DETECTOR
⊞	LIGHTING CONTROL SYSTEM MANUAL CONTROL POINT (IN EVENT OF IPAD / WHA FAILURE)

FIRE ALARM LEGEND	
⊙	POINT SMOKE DETECTOR, BLACK FINISH WHERE INSTALLED ON ASLE CEILING
⊙	POINT HEAT DETECTOR BLACK FINISH WHERE INSTALLED ON ASLE CEILING
⊙	POINT SMOKE DETECTOR WITH BASE MOUNTED SOUNDER BLACK FINISH WHERE INSTALLED ON ASLE CEILING
⊙	POINT SMOKE DETECTOR WITH BASE MOUNTED SOUNDER & BEACON
⊞	FIRE ALARM SOUNDER
⊙	VESDA MICROBORE SAMPLING POINT, BLACK FINISH
⊙	BASE MOUNTED FIRE ALARM VISUAL ALARM DEVICE
⊙	FIRE ALARM CALL POINT
⊞	FIRE ALARM CONTROL PANEL
⊞	MICROBORE ASPIRATION SYSTEM PANEL
---	SAMPLING PIPE / BEAM DETECTOR
⊞	BEAM DETECTOR CONTROLLER FOR INTELLIGENT AUTO-ALIGNING EMITTER
⊞	BEAM DETECTOR EMITTER
⊞	BEAM DETECTOR REFLECTOR

