



SCHEDULE OF LUMINAIRES	
S1	LED FLOODLIGHT, BLACK FINISH W/ 3 CIRCUIT TRACK ADAPTER, 28W OVAL, FLOOD AT HIGH LEVEL, 4000K COLOUR TEMPERATURE, DALI CONTROL. O - DENOTES LUMINAIRE TO DIRECTED AT ORGAN P - DENOTES LUMINAIRE TO DIRECTED AT PULPIT F - DENOTES LUMINAIRE TO DIRECTED AT FONT A - DENOTES LUMINAIRE TO DIRECTED AT ALTAR CA - DENOTES LUMINAIRE TO DIRECTED AT COAT OF ARMS
S2	LED FLOODLIGHT, BLACK FINISH W/ 3 CIRCUIT TRACK ADAPTER, 28W OVAL, FLOOD AT HIGH LEVEL, 4000K COLOUR TEMPERATURE, DALI CONTROL, POSITIONED TO UPPOINT CEILING
S3	AS S2 STYLE BUT WITH LOWER OUTPUT
B1	LED SPOTLIGHT WITH ADJUSTABLE BEAM ANGLE, 2.7K COLOUR TEMPERATURE, DALI CONTROL, BLACK FINISH MOUNTED AT HIGH LEVEL ARMED DOWN
C	SURFACE MOUNTED / RECESSED LED DOWNLIGHT
CE	AS TYPE 'P' BUT FITTED WITH 3 HOUR NON MAINTAINED EMERGENCY INTEGRAL BATTERY INVERTER UNIT.
D	LINEAR, 22.5W/M, 3000K RIGID LED STRIP TAPE COMPLETE WITH DRIVER.
E1	SURFACE MOUNTED BLACK 3 WATT SELF CONTAINED, NON MAINTAINED LED EMERGENCY LUMINAIRE, 3 HOUR DURATION
E2	HIGH LEVEL SURFACE MOUNTED BLACK 3 WATT NON MAINTAINED LED EMERGENCY LUMINAIRE, 3 HOUR DURATION

LIGHTING LEGEND	
✓	1500V 1 GANG 1 WAY LIGHTING SWITCH
O	DENOTES NUMBER OF GANGS
P	PRESSENCE DETECTOR
LM	LIGHTING CONTROL SYSTEM MANUAL CONTROL POINT (IN EVENT OF PAND/WIFI FAILURE)

FIRE ALARM LEGEND	
S	POINT SMOKE DETECTOR, BLACK FINISH WHERE INSTALLED ON AISLE CEILING
H	POINT HEAT DETECTOR, BLACK FINISH WHERE INSTALLED ON AISLE CEILING
S	POINT SMOKE DETECTOR WITH BASE MOUNTED SOUNDER/BLACK FINISH WHERE INSTALLED ON AISLE CEILING
SBS	POINT SMOKE DETECTOR WITH BASE MOUNTED SOUNDER & BEACON
SA	FIRE ALARM SOUNDER
V	VEGA MICROBORE SAMPLING POINT, BLACK FINISH
VAC	BASE MOUNTED FIRE ALARM VISUAL ALARM DEVICE
CP	FIRE ALARM CALL POINT
ACP	FIRE ALARM CONTROL PANEL
ASP	MICROBORE ASPARATION SYSTEM PANEL
SP	SAMPLING PIPE / BEAM DETECTOR
BECC	BEAM DETECTOR CONTROLLER FOR INTELLIGENT AUTO-ALIGNING EMITTER
BE	BEAM DETECTOR EMITTER
BR	BEAM DETECTOR REFLECTOR

NOTES

- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION FOR ELECTRICAL SERVICES INSTALLATION AND ALL ASSOCIATED ELECTRICAL DRAWINGS LISTED THEREIN.
- ALL ELECTRICAL SERVICES DRAWINGS SHALL BE READ IN CONJUNCTION WITH ALL ASSOCIATED ARCHITECTURAL, STRUCTURAL, DRAINAGE AND MECHANICAL SERVICES DRAWINGS.
- THE CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS ON SITE PRIOR TO COMMENCING CONSTRUCTION.
- ASBESTOS MAY BE PRESENT IN ANY PART OF THE BUILDING. THE ASBESTOS REGISTER SHOULD BE CONSULTED PRIOR TO ALL WORKS, AND ALL SITE OPERATIVES SHALL BE TRAINED IN ASBESTOS AWARENESS.

P2	14/10/22	STAGE 3 ISSUE
P1	07/10/22	PRELIMINARY FOR ARCHITECT'S COMMENT
REV	DATE	DESCRIPTION



ENVIRONMENTAL  
ENGINEERING  
PARTNERSHIP  
CONSULTING ENGINEERS  
www.eep.co.uk  
01494 464 544

CLIENT	ST LAWRENCE CHURCH PCC
PROJECT	PROJECT INSPIRE ST LAWRENCE CHURCH LECHLADE
TITLE	PROPOSED LIGHTING, EMERGENCY LIGHTING AND FIRE ALARM SECTIONS
DRAWN	KH / IP
CHECKED	IP / PQ
DRAWING No.	4184 E 03
SCALE	1:50 @ A0
DATE	SEP 2022
REVISION	P2